

പതിനാലാം കേരള നിയമസഭ


പതിമൂന്നാം സമ്മേളനം

നക്ഷത്ര ചിഹ്നമിടാത്ത
ചോദ്യം നമ്പർ:2964

07.12.2018-ലെ മറുപടി

പാറശ്ശാല മണ്ഡലത്തിലെ കാലഹരണപ്പെട്ട പൈപ്പ് ലൈനുകൾ

ചോദ്യം		മറുപടി	
ശ്രീ.സി.കെ. ഹരീന്ദ്രൻ		കെ.കൃഷ്ണൻ കുട്ടി (ജലവിഭവ വകുപ്പുമന്ത്രി)	
(എ)	പാറശ്ശാല മണ്ഡലത്തിലെ കാലഹരണപ്പെട്ട പൈപ്പ് ലൈനുകൾ ഇടക്കിടെ പൊട്ടുന്നതു കാരണം റോഡുകൾ തകരുന്ന കാര്യം ശ്രദ്ധയിൽപ്പെട്ടിട്ടുണ്ടോ;	(എ)	ഉണ്ട്.
(ബി)	പ്രസ്തുത പൈപ്പ് ലൈനുകൾ മാറ്റി പുതിയവ സ്ഥാപിക്കുന്നതിനായുള്ള നടപടികൾ സ്വീകരിക്കുമോ; വിശദമാക്കുമോ?	(ബി)	പൈപ്പ് ലൈനുകൾ മാറ്റി പുതിയവ സ്ഥാപിക്കുന്നതിനായി 2018-19 സ്റ്റേറ്റ് പ്ലാൻ ഫണ്ടിൽ ഉൾപ്പെടുത്തി 438.50 ലക്ഷം രൂപയുടെ ഭരണാനുമതി നൽകിയിട്ടുണ്ട്. ആയതിൽ ഉൾപ്പെട്ട പ്രവൃത്തികളുടെ ലിസ്റ്റ് അനുബന്ധമായി ചേർക്കുന്നു. ഇതു സംബന്ധിച്ച് തുടർ നടപടികൾ കേരള വാട്ടർ അതോറിറ്റി സ്വീകരിച്ചു വരുന്നു.


 സെക്ഷൻ ഓഫീസർ

**LIST OF WORKS UNDER PARASSALA CONSTITUENCY SANCTIONED UNDER STATE
PLAN 2018-19**

Sl. No.	Name of work	Amount (Rs. In lakhs)
1	RWSS to Parassala - Replacing old and damaged 80mm AC Class 20 distribution line with 110mm PVC 6kg/cm ² from Thekkumkara Temple to Alampara Substation in Parassala Panchayath (2000m)	40.71
2	CWSS to Amboori - Replacing old and damaged 200mm AC Class 20 distribution main with 200mm DI K9 from Kallimoodu to Kiliyoor in Vellarada Panchayath (1000m)	110.90
3	CWSS to Amboori - Replacing old and damaged 250mm AC Class 20 distribution main with 250mm DI K9 from Thudiyankonam to Kuttappu to Kulavankuzhy in Amboori Panchayath (1500m)	166.19
4	RWSS to Parassala - Replacing old and damaged 80mm AC Class 20 distribution line with 90mm PVC 6kg/scm from Gandhi park to GHS in Parassala Panchayath (850m)	21.35
5	RWSS to Kunnathukal - Replacing old and damaged 110mm PVC distribution main with 110mm PVC 6kg/scm from Paliyode to Chamavila in Kunnathukal Panchayath (760m)	13.20
6	RWSS to Aryancode - Replacing old and damaged 200mm AC Class 15 distribution main with 300mm DI K9 from Nedinjikunnu GLSR to Mylachal Road in Aryancode Panchayath (425m)	25.39
7	RWSS to Dhanuvachapuram - Replacing old and damaged 80mm GI pumping main with 110mm PVC 10 kg/scm from Eithukondakani ph to ITI GLSR in Kollayil Panchayath (2500m)	53.15
8	RWSS to Aryancode - Replacing old and damaged 100mm AC Class 20 pumping main with 110mm PVC from karikkarathala to Ozhukupara GLSR in Aryancode Panchayath (600M)	7.61
	Total	438.50


Section Officer